

City of Clio - WWTP Power Factor and Power Quality Improvement Analysis

Pre-Date	kWh	Days	kWh/Day
Jan-05	20960	15	1397
Feb-05			
Mar-05	37280	28	1331
Apr-05	42360	31	1366
May-05	37240	30	1241
Jun-05	38280	31	1235
Jul-05	47920	31	1546
Aug-05	44560	31	1437
Sep-05	43560	30	1452
Oct-05	40680	31	1312
Nov-05	39840	30	1328
Dec-05	61280	49	1251
	453960	337	1347

Post Date	kWh	Days	kWh/Day	
Feb-06	14440	28	516	
Mar-06	31840	32	995	
Apr-06	35120	29	1211	
May-06	34520	30	1151	
Jun-06	32760	33	993	
Jul-06	28360	29	978	
Aug-06	28880	30	963	
Sep-06	27080	32	846	
Oct-06				
Nov-06				
Dec-06				
	233000	243	959	Change
				-28.82%

Southern Power Solutions

400 East Boulevard, Suite 104
 Montgomery, AL 36117
 334.409.0460